

Prepared For:

ljk
319 SW Washington St.
portland OR
97204

Conducted By:

Lucas Klesch

Test Period:

11/7/05 – 11/13/05

Monitor ID:

#8407

This report offers recommendations so you can make informed decisions about your family's health, comfort and safety. Knowing what's in the air you breathe and what you can do about it has never been more important. If you have additional questions, visit www.airadvice.com or call **1-866-247-4800**.

What We Tested

What We Found

Possible Causes

Recommended Action

HEALTH



Action Recommended

Particle Allergens, Chemical Pollutants, Carbon Dioxide

- ▶ **Particle Allergens:**
Levels elevated
- ▶ **Chemical Pollutants:**
Levels elevated
- ▶ **Carbon Dioxide:**
Levels improvable

- Inadequate filtration
- Inadequate fresh air introduction
- Build-up of chemical pollutants

- Upgrade ventilation
- Add VOC reduction device
- Remove VOC sources

COMFORT



Action Recommended for Sensitive Individuals

Temperature, Relative Humidity

- ▶ **Temperature:**
Somewhat too warm
- ▶ **Relative Humidity:**
Levels acceptable

- Inadequate temperature setpoint or inadequate thermostat

- Check thermostat for proper setpoint and function

SAFETY



Action Necessary

Carbon Monoxide

- ▶ **Carbon Monoxide:**
Levels significantly elevated

- Carbon monoxide source in home or garage

- Remove carbon monoxide source in home or garage