

# Ultrasonic Air Leak Survey 08/09~8/10/2011

## \$31,600 Discovered Losses

Consultant;

Scott Milne BPI, RESNET, LEED

National Energy Technologies LLC

800-984-0332

www.NationalEnergyTech.com

Data collected by: Christopher Turcich

### Thank you for selecting National Energy Techn

## Compressed Air Remediation

We discovered 95 measurable air leaks 16 overhead leaks.


and

#### **Available Savings**

\$30,400

energy savings

Chart of accrued savings based on one month repair time and 95% repair rate.



519,000 kwh 339 cfm / 40 hp

348 tons

Annual power consumed to generate compressed air lost through leaks.

Total air loss and horsepower equivalency.

Carbon emission from utility to generate above power

#### Top Ten Air Leak

ref	description	annual cost
46	Yokes Line 2 Chucker area	\$ 729
12	OP 260 RIO Panel #5	\$ 464
41	TR1K/2K Assembly Cell Flow Test/Pack	\$ 464
47	Yokes Line 2 Turn + Grind	\$ 445
50	Yokes Line 2	\$ 417
20	OP Pre Assembly Cell Two	\$ 407
22	HSG Deburr Washer 1	\$ 379
8	HSG Deburr Washer #2	\$ 379
48	Yokes Line 2 Drill/Deflector Assembly	\$ 369
31	Alfing #3	\$ 369

See Inspection and Calculation Methodology on following pages

# Job 110800-1 Report Index

ret#	description		page (	cost
1	compressor room	Sullair LS-25S 10045 (250hp)	1	\$ 313
2	compessor room	LS-25 200L ACAC #1	2	\$ 20
3	compressor room	receiver tank drain	3	\$ 33
4	Maintenance area	air line quick-connect near chop saw	4	\$ 31
5	Long Shaft Cell Lathe #3	SMN001781	5	\$ 369
6	Long Shaft Cell Lathe #3	air feed to filter	6	\$ 32
7	Long Shaft Cell Lathe #2	SMN001782	7	\$ 76
3	HSG Deburr Washer #2	load side Numatic valve near stairs	8	\$ 37
9	HSG Disassembly	back of east station	9	\$ 26
10	HSG Disassembly	east tank cart	10	\$ 29
11	Deburr Operation	Mori Seiki SH400 #2	11	\$ 16
12	OP 260 RIO Panel #5	nipple into union tee	12	\$ 46
13	Shaft Polisher Robot	Z axis advance valve "A" port	13	\$ 26
14	Final Clean Washer #3	load side air valve	14	\$ 16
15	Final Clean Washer #3	Valve Bank 8 OP310	15	\$ 29
16	Final Assembly Cell One	Machine 55	16	\$ 25
١7	Final Assembly Cell One	screw feeder	17	\$ 17
18	Final Assembly Cell One	Oiler 2	18	\$ 20
19	OP Pre Assembly Cell Two	hose fitting at swivel	19	\$ 34
20	OP Pre Assembly Cell Two	cap on valve lubricator	20	\$ 40
21	Alfing #4	operator station air nozzle	21	\$ 21
22	HSG Deburr Washer 1	filter drain	22	\$ 37
23	OP 110D RIO Panel (near Alfing 4)		23	\$ 33
24	In Process Inspection Alfing 1~2	back side regulator	24	\$ 18
25	Conveyor Line behind Alfing #1	OP110 A	25	\$ 67
26	Conveyor Line behind Alfing #1	OP 110A	26	\$ 13
27	Washer 1	conveyor air valve under stairway	27	\$ 16
28	Belmont SY-2535 EDM Drilling Machine	SMN001942	28	\$ 32
29	HSG Pre-Assembly One Housings	air nozzle at quick connect	29	\$ 20
30	HSG Pre-Assembly One	OP200A Air Valve	30	\$ 21
31	Alfing #3	operator station air nozzle	31	\$ 36
32	Alfing #3	operator station air nozzle	32	\$ 31
33	Alfing #3	operator station air nozzle	33	\$ 32
	/ Pad Machine #4	SH400	34	\$ 32
35	W Pad Machine 5	main filter/regulator	35	
36	Quality Control	crush height gauge	36	
37	East wall Tear Down Inspection	fitting threads into quick-connect	36 37	\$ 27 \$ 16
38	TR1K/2K Shaft Cell Grind/Polish	Shigoya Grinder	38	
39	TR1K/2K Housing Cell Machining	S+W #1	39	\$ 27
10	TR1K/2K Housing Cell Machining	Mori Seiki SH403	39 40	\$ 30
11	TR1K/2K Assembly Cell Flow Test/Pack	Balance Shaft + Housing Gauge		\$ 12 \$ 46
12	TR1K/2K Assembly Cell Flow Test/Pack	Sub-Assembly Upper/Lower fixture	41 42	
13	TR1K/2K Assembly Cell Flow Test/Pack	Test Gauge Stand	42	\$ 22 ¢ 26
14	Yokes Line 2 Chucker	along east-west aisle	43	\$ 26
45	Yokes Line 2 Chucker	lube pump	44 45	\$ 21
	TORGO EITIC E CHACKET	iace paint	45	\$ 26



## **Ultrasonic Compressed Air Survey**

M

staff: C. TURCICH cert: UET2007245

equip: 9000MPH serial: 928155

report: 110800-1

#### \$17,300 / 184 cfm / 290,000 kwh loss identified

Measurements taken in accordance with ASTM E1002-05. See Summary Report for calculation method.

6	Long Shaft Cell Lathe #3		
\$ 322	air feed to filter		
8/9/2011	nipple upstream of valve		
56 db			
100 psi			
3.4 cfm			
0		repair time/materials	
repaired	date:		
repaired by:			
ugrified -		repair notes	
verified	date:		
7.			
verified by:			