

<b>Equipment Group</b>	<b>AVG Modes per Group</b>	<b>STD Modes per Group</b>	<b># Types per Group</b>
Cable - LV	10.8	1.9	4.0
Cable - Power	22.6	4.5	41.0
Comp. Air & Gas	67.3	22.4	8.0
CNC	322.7	47.9	3.0
Coupling, FD, Gearbox	32.3	31.8	15.0
Electrical Bus - HV	70.0		1.0
Emission Control	78.8	34.1	5.0
Engine	116.0		1.0
Fan, Blower	54.3	34.5	8.0
Filter, Strainer	17.6	21.3	12.0
FLEX - Emergency	203.0	39.7	16.0
Generator - Electric	134.0	82.1	12.0
HX - Condensor	67.3	28.1	3
HX - Cooling Tower	143.0	67.2	8.0
HX - General	45.0	15.0	9.0
Heater	22.5	12.0	4.0
HVAC	89.2	17.7	5.0
I&C - Control	14.7	9.8	41.0
I&C - Indication	11.2	7.4	5.0
Material Handling	57.8	22.6	5.0
Mechanical	38.2	38.7	10.0
Motor - DC	81.0	6.2	3.0
Motor - LV	102.8	19.7	13.0
Motor - MV	164.3	20.7	26.0
Power Supply - AC/DC	20.0		1.0
Power Supply - Battery	43.0	13.3	6.0
Power Supply - DC/AC	33.5	9.2	2.0
Power Supply - Solar	80.0		1.0
Pump - Horiz - Multi	125.2	8.3	13.0
Pump - Horiz - Single	96.8	28.9	16.0
Pump - Pos Disp	102.0	65.7	7.0
Pump - Vacuum	50.0	42.4	2.0
Pump - Vertical	96.3	33.8	8.0
Relay	22.7	6.0	9.0
Switchgear - MV & LV	35.9	17.3	16.0
Transformer - Power	58.8	38.9	26.0
T&D - Substation	38.9	22.9	15.0
T&D - Poles	31.4	1.8	19.0
Turbine - Gas	95.9	83.0	39.0
Turbine - Hydro	96.0		1.0
Turbine - Steam	95.7	112.0	20.0
Turbine - Process	142.7	79.3	9.0
Valve	74.9	33.0	33.0
<b>Counts</b>	<b>43</b>	<b>43</b>	<b>501</b>

### ASL Equipment Groups, R13



